

令和6年5月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	19.8	14.8	1.0	7.60							
2	晴	17.0	14.0	1.2	7.65							
3	晴	22.0	13.8	0.8	7.68							
4	晴	21.8	13.8	0.9	7.67							
5	晴	22.0	14.0	0.9	7.66							
6	曇	20.0	14.0	1.3	7.68							
7	雨	18.0	14.5	1.0	7.60	40.1	38.6	134	6.3	0.06	<0.02	
8	晴	20.5	14.6	0.9	7.68							
9	曇	13.7	13.8	0.8	7.62							
10	晴	21.0	12.7	0.9	7.84							
11	晴	20.2	14.0	0.4	7.70							
12	曇	20.3	14.0	0.9	7.73							
13	雨	19.7	15.7	13.0	7.54							
14	曇	17.5	14.4	2.4	7.72							
15	晴	24.0	13.8	0.8	7.76							
16	雨	17.3	15.0	1.0	7.70							
17	晴	23.0	13.5	0.9	7.82							
18	晴	25.5	14.0	0.6	7.72							
19	曇	19.0	14.0	0.7	7.68							
20	晴	20.6	14.8	13.5	7.59	33.4	33.7	123	4.4	0.57	<0.02	
21	晴	25.0	14.7	1.5	7.70							
22	曇	22.0	15.2	0.6	7.72							
23	曇	20.0	14.7	1.0	7.66							
24	曇	22.5	14.6	1.0	7.72							
25	曇	22.2	14.7	0.9	7.70							
26	曇	21.6	14.5	0.8	7.70							
27	雨	18.8	15.0	0.5	7.72							
28	雨	21.2	15.0	0.1	7.58							
29	曇	20.3	16.0	25.4	7.53							
30	晴	25.7	15.0	2.1	7.68							
31	雨	18.2	15.0	1.3	7.64							
平均		20.7	14.4	2.6	7.68	36.8	36.2	129	5.4	0.32	<0.02	
最高		25.7	16.0	25.4	7.84	40.1	38.6	134	6.3	0.57	<0.02	
最低		13.7	12.7	0.1	7.53	33.4	33.7	123	4.4	0.06	<0.02	