

令和6年6月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	22.0	15.0	1.0	7.72							
2	晴	21.8	15.0	1.0	7.72							
3	曇	22.2	14.2	1.0	7.68	38.5	41.5	149	5.7	0.07	<0.02	
4	晴	23.4	14.3	1.2	7.75							
5	晴	24.3	14.5	1.0	7.73							
6	晴	23.1	14.7	0.9	7.67							
7	曇	24.0	14.5	0.6	7.66							
8	晴	25.7	14.3	0.6	7.73							
9	晴	22.8	14.4	0.6	7.63							
10	曇	20.3	14.6	0.9	7.66							
11	曇	24.8	15.0	0.5	7.65							
12	晴	25.7	15.3	1.3	7.68							
13	晴	22.7	15.0	0.6	7.61							
14	晴	28.2	14.8	0.4	7.70							
15	晴	25.2	15.0	0.7	7.63							
16	曇	22.0	15.0	0.9	7.49							
17	晴	27.6	15.2	0.6	7.62	41.1	41.4	155	8.1	0.05	<0.02	
18	雨	17.3	15.1	2.5	7.56							
19	晴	27.0	14.8	2.2	7.70							
20	曇	26.4	15.0	1.0	7.79							
21	雨	17.5	15.0	0.8	7.57							
22	晴	26.7	14.5	0.8	7.63							
23	雨	18.8	15.0	1.0	7.72							
24	晴	29.0	15.6	0.8	7.79							
25	曇	25.1	15.2	0.6	7.73							
26	晴	27.5	15.8	1.0	7.62							
27	曇	27.5	15.3	0.7	7.64							
28	雨	21.0		0.8	7.57							サンプリングボ ンプ故障のため 水温データなし
29	雨	22.3		3.3	7.56							
30	曇	23.7	15.0	1.1	7.60							
平均		23.9	14.9	1.0	7.66	39.8	41.5	152	6.9	0.06	<0.02	
最高		29.0	15.8	3.3	7.79	41.1	41.5	155	8.1	0.07	<0.02	
最低		17.3	14.2	0.4	7.49	38.5	41.4	149	5.7	0.05	<0.02	