

令和6年7月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	29.0	15.8	0.8	7.62	39.5	36.9	149	5.7	0.03	<0.02	
2	曇	24.4	15.4	1.0	7.54							
3	晴	29.2	15.8	0.3	7.62							
4	晴	30.9	16.0	0.8	7.61							
5	晴	33.2	15.8	0.7	7.67							
6	晴	31.2	16.1	0.6	7.64							
7	晴	29.6	15.5	0.8	7.75							
8	晴	30.0	15.9	0.7	7.63							
9	曇	28.0	15.8	0.6	7.62							
10	曇	30.7	15.4	0.7	7.80							
11	曇	29.5	16.0	0.8	7.67							
12	雨	24.5	15.4	0.5	7.53							
13	晴	26.8	15.5	0.6	7.68							
14	曇	26.0	15.5	0.7	7.57							
15	曇	29.5	16.0	0.7	7.54							
16	雨	23.2	17.1	20.3	7.50	36.8	35.9	157	4.8	0.82	0.04	
17	曇	25.7	17.0	10.0	7.61							
18	晴	31.0	16.0	0.8	7.67							
19	晴	28.0	16.2	0.7	7.64							
20	晴	30.5	16.1	0.6	7.66							
21	晴	33.0	16.7	0.3	7.70							
22	晴	30.5	16.0	0.7	7.66							
23	晴	30.8	16.1	0.5	7.68							
24	晴	31.0	16.3	0.9	7.55							
25	晴	28.2	17.0	0.5	7.57							
26	晴	29.3	15.9	0.5	7.63							
27	曇	30.8	16.0	0.4	7.62							
28	晴	31.3	15.5	0.6	7.66							
29	晴	35.3	16.2	0.6	7.62							
30	晴	34.2	15.8	0.4	7.60							
31	晴	31.8	16.7	0.5	7.82							
平均		29.6	16.0	1.6	7.63	38.2	36.4	153	5.3	0.43	<0.02	
最高		35.3	17.1	20.3	7.82	39.5	36.9	157	5.7	0.82	0.04	
最低		23.2	15.4	0.3	7.50	36.8	35.9	149	4.8	0.03	<0.02	