

令和6年8月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	33.5	16.7	0.7	7.82							
2	晴	31.8	16.8	1.1	7.60							
3	晴	30.1	16.0	0.6	7.63							
4	曇	33.0	16.2	0.6	7.67							
5	晴	32.4	16.8	0.7	7.71	43.0	43.7	146	7.7	0.04	<0.02	
6	曇	32.5	16.3	0.7	7.76							
7	晴	31.0	16.2	0.5	7.64							
8	晴	30.8	16.1	1.6	7.65							
9	晴	33.2	16.2	0.6	7.64							
10	晴	34.2	16.2	0.9	7.62							
11	晴	31.8	16.1	0.5	7.62							
12	曇	31.0	16.0	0.5	7.62							
13	晴	31.7	16.0	0.2	7.64							
14	晴	33.0	16.7	0.3	7.63							
15	晴	32.7	16.0	0.5	7.56							
16	曇	29.0	16.2	0.5	7.60							
17	晴	36.8	16.2	1.2	7.61							
18	晴	30.0	16.0	0.3	7.49							
19	晴	33.0	16.2	0.6	7.58	43.7	43.5	123	7.9	0.04	<0.02	
20	曇	29.0	16.0	0.7	7.56							
21	晴	29.7	15.7	0.5	7.52							
22	曇	28.0	17.0	1.2	7.65							
23	曇	28.4	16.1	0.7	7.58							
24	曇	29.1	16.0	0.5	7.56							
25	曇	29.2	16.3	1.9	7.59							
26	晴	27.6	16.3	0.7	7.40							
27	雨	26.0	17.0	2.4	7.58							
28	曇	25.4	16.9	4.0	7.57							
29	雨	23.0	16.0	0.8	7.57							
30	雨	25.2	19.8	175.4	7.61							
31	曇	32.2										断水のため水温、濁度、pHの結果なし
平均		30.5	16.4	6.7	7.61	43.4	43.6	135	7.8	0.04	<0.02	
最高		36.8	19.8	175.4	7.82	43.7	43.7	146	7.9	0.04	<0.02	
最低		23.0	15.7	0.2	7.40	43.0	43.5	123	7.7	0.04	<0.02	