

令和6年9月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	26.5										断水のため水温、濁度、pHの結果なし
2	晴	29.8	17.3	3.1	7.57	40.1	42.7	135	3.8	0.92	0.03	
3	曇	27.8	15.8	1.5	7.56							
4	晴	28.5	15.5	2.5	7.58							
5	晴	29.7	15.6	1.8	7.60							
6	晴	29.7	15.8	0.9	7.62							
7	晴	30.0	16.0	1.2	7.57							
8	晴	32.8	15.2	1.6	7.60							
9	晴	31.8	15.5	0.8	7.60							
10	晴	29.8	15.7	0.8	7.63							
11	晴	31.0	15.8	1.0	7.50							
12	晴	30.5	16.0	0.7	7.64							
13	晴	30.0	16.0	0.9	7.57							
14	晴	30.2	15.6	0.6	7.59							
15	曇	31.0	16.0	0.7	7.59							
16	曇	30.2	15.8	1.3	7.49							
17	晴	28.0	16.0	0.6	7.57	41.1	43.5	136	5.7	0.05	<0.02	
18	晴	31.0	15.8	0.7	7.54							
19	晴	29.7	16.0	0.8	7.59							
20	晴	32.2	16.0	1.1	7.61							
21	晴	32.0	16.8	0.7	7.62							
22	曇	27.8	16.2	1.4	7.55							
23	曇	24.8	15.8	1.1	7.62							
24	晴	27.0	15.8	0.6	7.62							
25	曇	21.1	14.1	1.0	7.51							
26	晴	29.1	15.0	0.8	7.67							
27	曇	24.1	15.4	0.8	7.43							
28	曇	25.2	15.1	0.6	7.54							
29	曇	24.0	15.3	1.2	7.48							
30	晴	25.3	15.0	1.1	7.53							
31												
平均		28.7	15.7	1.1	7.57	40.6	43.1	136	4.8	0.49	<0.02	
最高		32.8	17.3	3.1	7.67	41.1	43.5	136	5.7	0.92	0.03	
最低		21.1	14.1	0.6	7.43	40.1	42.7	135	3.8	0.05	<0.02	