

令和6年10月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	29.2	15.0	0.8	7.56	41.6	43.6	122	7.2	0.08	<0.02	
2	晴	27.4	15.3	0.7	7.58							
3	晴	30.0	15.3	0.9	7.58							
4	雨	23.0	17.7	11.2	7.46							
5	雨	23.2	16.0	1.2	7.57							
6	曇	27.5	16.8	4.2	7.54							
7	晴	28.0	16.0	2.5	7.64							
8	晴	25.2	15.9	0.9	7.60							
9	雨	17.4	15.5	1.9	7.59							
10	晴	20.5	14.2	1.0	7.65							
11	晴	24.3	14.7	1.1	7.61							
12	晴	25.6	14.7	1.0	7.59							
13	晴	25.6	14.2	0.9	7.56							
14	晴	22.3	14.0	0.6	7.58							
15	晴	24.5	14.2	0.8	7.57	42.4	44.0	120	6.1	0.11	<0.02	
16	曇	21.2	14.4	0.8	7.60							
17	曇	26.6	15.0	0.5	7.64							
18	曇	21.5	14.6	0.7	7.58							
19	曇	26.8	14.8	0.6	7.60							
20	曇	13.9	14.8	0.6	7.58							
21	晴	21.0	13.0	0.4	7.60							
22	晴	22.3	13.7	0.6	7.67							
23	雨	19.0	14.5	0.4	7.60							
24	晴	27.4	15.0	0.9	7.62							
25	曇	20.2	14.8	0.8	7.61							
26	曇	19.0	14.3	0.7	7.58							
27	曇	21.4	14.2	0.4	7.63							
28	曇	19.4	14.5	0.2	7.59							
29	雨	16.0	14.0	0.4	7.60							
30	曇	17.6	14.1	1.0	7.62							
31	曇	21.8	13.6	0.5	7.68							
平均		22.9	14.8	1.3	7.60	42.0	43.8	121	6.7	0.10	<0.02	
最高		30.0	17.7	11.2	7.68	42.4	44.0	122	7.2	0.11	<0.02	
最低		13.9	13.0	0.2	7.46	41.6	43.6	120	6.1	0.08	<0.02	