

令和6年11月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	20.4	14.0	0.9	7.67							
2	雨	15.7	14.1	0.9	7.59							
3	曇	15.0	15.0	0.5	7.54							
4	曇	21.0	13.7	2.1	7.55							
5	曇	18.7	13.7	1.3	7.61	42.5	45.9	119	6.0	0.07	<0.02	
6	晴	21.2	14.2	0.7	7.57							
7	晴	17.7	13.1	0.7	7.57							
8	曇	12.5	13.0	0.6	7.62							
9	曇	19.7	12.8	0.7	7.64							
10	曇	13.7	13.0	0.7	7.60							
11	曇	15.7	14.1	0.7	7.63							
12	曇	15.8	13.8	0.6	7.64							
13	晴	22.6	13.5	0.7	7.72							
14	晴	19.2	13.8	0.5	7.68							
15	曇	17.8	14.1	1.2	7.68							
16	曇	17.5	14.0	0.5	7.66							
17	晴	19.2	14.0	0.3	7.66							
18	曇	18.0	14.2	0.4	7.70	43.6	45.4	115	6.8	0.07	<0.02	
19	曇	12.6	12.7	0.6	7.67							
20	雨	13.8	12.1	0.5	7.68							
21	晴	15.7	12.9	0.3	7.72							
22	晴	16.3	12.6	0.6	7.57							
23	晴	15.2	11.8	0.5	7.71							
24	曇	12.0	12.5	0.4	7.69							
25	晴	12.3	12.2	0.5	7.66							
26	曇	10.8	11.8	0.3	7.73							
27	曇	15.2	13.8	3.9	7.64							
28	晴	18.2	12.2	0.4	7.72							
29	晴	16.0	11.7	0.7	7.70							
30	晴	13.4	11.5	0.5	7.42							
31												
平均		16.4	13.2	0.8	7.64	43.1	45.7	117	6.4	0.07	<0.02	
最高		22.6	15.0	3.9	7.73	43.6	45.9	119	6.8	0.07	<0.02	
最低		10.8	11.5	0.3	7.42	42.5	45.4	115	6.0	0.07	<0.02	