

令和6年12月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	15.5	11.5	0.4	7.63							
2	晴	13.8	12.0	0.4	7.66	44.4	47.7	113	7.4	0.03	<0.02	
3	晴	16.2	12.0	0.3	7.62							
4	晴	16.3	11.8	0.4	7.67							
5	晴	14.7	12.5	0.6	7.58							
6	晴	14.5	11.5	0.3	7.64							
7	晴	14.0	10.7	0.3	7.69							
8	晴	11.3	11.2	0.3	7.65							
9	曇	9.0	10.5	0.4	7.71							
10	晴	13.0	10.6	0.5	7.70							
11	晴	11.1	11.0	0.3	7.65							
12	曇	9.7	10.9	0.4	7.75							
13	曇	5.0	10.4	0.4	7.66							
14	晴	15.0	11.0	0.3	7.78							
15	晴	8.0	10.1	0.3	7.74							
16	晴	8.2	10.1	0.2	7.72	43.8	45.9	123	6.3	0.03	<0.02	
17	晴	12.2	10.2	0.4	7.68							
18	晴	12.3	10.7	0.3	7.59							
19	曇	8.5	11.3	0.3	7.53							
20	晴	10.5	10.8	0.3	7.64							
21	晴	14.6	10.8	0.3	7.60							
22	晴	14.5	11.0	0.3	7.61							
23	晴	7.5	10.4	0.4	7.64							
24	晴	11.2	10.2	0.3	7.63							
25	晴	5.8	9.7	0.6	7.63							
26	晴	14.0	11.2	0.2	7.60							
27	晴	11.5	11.0	0.3	7.60							
28	晴	7.2	11.0	0.3	7.68							
29	晴	9.2	10.2	0.3	7.67							
30	曇	7.3	11.0	0.3	7.66							
31	晴	10.8	10.7	0.2	7.62							
平均		11.4	10.9	0.3	7.65	44.1	46.8	118	6.9	0.03	<0.02	
最高		16.3	12.5	0.6	7.78	44.4	47.7	123	7.4	0.03	<0.02	
最低		5.0	9.7	0.2	7.53	43.8	45.9	113	6.3	0.03	<0.02	