

令和7年2月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	8.2	10.8	0.3	7.53							
2	雨	5.0	11.1	0.4	7.58							
3	曇	8.1	11.5	0.3	7.62	42.7	45.0	117	8.6	<0.02	<0.02	
4	晴	10.0	10.8	0.3	7.60							
5	晴	6.5	10.4	0.3	7.48							
6	晴	4.0	10.0	0.3	7.60							
7	晴	5.0	10.1	0.5	7.67							
8	晴	5.1	10.3	0.3	7.64							
9	晴	8.8	10.0	0.2	7.64							
10	晴	7.7	10.3	0.2	7.60							
11	晴	7.8	10.4	0.2	7.68							
12	曇	5.7	10.5	0.4	7.67							
13	晴	17.4	12.0	0.5	7.60							
14	晴	9.7	10.7	0.5	7.63							
15	曇	11.5	11.0	0.3	7.65							
16	晴	12.3	11.8	0.3	7.59							
17	晴	13.8	11.3	0.4	7.63	42.3	43.0	123	9.2	<0.02	<0.02	
18	晴	6.6	10.5	0.3	7.66							
19	晴	8.8	10.2	0.2	7.64							
20	晴	6.0	10.0	0.3	7.64							
21	晴	7.5	10.2	0.2	7.66							
22	晴	8.8	10.0	0.3	7.60							
23	晴	7.7	10.0	0.4	7.48							
24	晴	8.3	10.3	0.2	7.63							
25	晴	4.0	11.0	0.3	7.54							
26	晴	12.0	10.1	0.3	7.58							
27	晴	14.5	10.8	0.6	7.56							
28	晴	12.5	11.0	0.3	7.67							
29												
30												
31												
平均		8.7	10.6	0.3	7.61	42.5	44.0	120	8.9	<0.02	<0.02	
最高		17.4	12.0	0.6	7.68	42.7	45.0	123	9.2	<0.02	<0.02	
最低		4.0	10.0	0.2	7.48	42.3	43.0	117	8.6	<0.02	<0.02	