

令和7年3月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 ℃	水 質 試 験 結 果 (滝戸沈砂池：原水)									備 考
			水 温 ℃	濁 度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	13.5	11.2	0.4	7.66							
2	曇	16.0	11.5	0.5	7.67							
3	雨	10.7	13.0	1.1	7.50	37.6	40.7	105	6.4	0.13	<0.02	
4	曇	5.1	11.3	0.5	7.65							
5	雨	7.5	10.0	0.8	7.63							
6	曇	9.8	12.0	0.5	7.65							
7	晴	11.0	10.7	0.9	7.71							
8	曇	4.7	10.9	0.3	7.67							
9	晴	9.0	11.3	0.5	7.68							
10	晴	13.0	11.0	0.5	7.68							
11	晴	11.0	11.8	0.4	7.64							
12	曇	15.2	12.0	0.6	7.72							
13	曇	17.0	12.5	0.6	7.70							
14	晴	17.7	12.0	0.6	7.74							
15	曇	10.0	11.8	0.4	7.68							
16	雨	5.2	11.3	0.9	7.62							
17	晴	14.5	11.7	0.8	7.68	42.1	45.0	116	8.7	0.02	<0.02	
18	晴	10.5	11.0	0.5	7.66							
19	曇	6.8	11.2	0.6	7.59							
20	曇	5.8	11.2	0.5	7.60							
21	晴	13.2	11.2	0.5	7.67							
22	晴	16.4	11.3	0.4	7.65							
23	晴	19.5	12.0	0.4	7.75							
24	曇	15.6	12.3	0.6	7.62							
25	曇	12.9	12.8	0.7	7.56							
26	晴	22.7	13.0	0.9	7.61							
27	晴	21.2	12.6	0.6	7.59							
28	晴	22.5	14.1	1.7	7.64							
29	雨	10.8	13.3	0.9	7.52							
30	晴	12.0	11.8	0.7	7.64							
31	曇	8.1	12.0	0.6	7.62							
平均		12.5	11.8	0.6	7.65	39.9	42.9	111	7.6	0.08	<0.02	
最高		22.7	14.1	1.7	7.75	42.1	45.0	116	8.7	0.13	<0.02	
最低		4.7	10.0	0.3	7.50	37.6	40.7	105	6.4	0.02	<0.02	