

令和8年1月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 ℃	水 質 試 験 結 果 (滝戸沈砂池 : 原水)									備 考
			水 温 ℃	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	12.2	11.2	0.2	7.88							
2	晴	11.0	11.5	0.3	7.85							
3	晴	9.8	11.0	0.3	7.78							
4	晴	11.0	10.5	0.2	7.80							
5	晴	11.7	10.8	0.3	7.81	45.2	47.1	114	4.3	<0.02	<0.02	
6	晴	6.5	10.5	0.3	8.06							
7	曇	7.9	10.5	0.3	7.80							
8	晴	10.0	11.8	0.2	7.77							
9	晴	10.5	10.5	0.2	7.59							
10	晴	12.6	11.0	0.7	7.56							
11	曇	11.9	12.0	0.7	7.54							
12	晴	7.5	10.5	0.5	7.56							
13	晴	10.2	10.2	0.4	7.66							
14	晴	11.5	11.0	0.7	7.61							
15	晴	10.5	10.5	0.3	7.60							
16	晴	17.5	11.0	0.4	7.64							
17	晴	14.5	11.2	0.4	7.61							
18	晴	15.5	11.1	0.5	7.60							
19	晴	10.5	11.5	0.5	7.55	43.0	46.9	118	9.8	0.04	<0.02	
20	晴	15.0	11.9	0.4	7.57							
21	曇	5.0	11.0	0.4	7.60							
22	晴	8.0	10.5	0.5	7.57							
23	晴	9.0	10.0	0.4	7.61							
24	晴	10.0	10.0	0.4	7.63							
25	晴	8.5	10.1	0.5	7.62							
26	晴	7.2	10.0	0.5	7.62							
27	晴	8.0	10.5	0.5	7.56							
28	曇	5.5	10.5	0.5	7.60							
29	晴	8.5	11.0	0.5	7.59							
30	晴	8.0	10.5	0.2	7.62							
31	晴	9.0	10.1	0.3	7.67							
平均		10.1	10.8	0.4	7.66	44.1	47.0	116	7.1	0.03	<0.02	
最高		17.5	12.0	0.7	8.06	45.2	47.1	118	9.8	0.04	<0.02	
最低		5.0	10.0	0.2	7.54	43.0	46.9	114	4.3	<0.02	<0.02	