

令和 2年 5月分

静清工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (配水 : 配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	22.0	9.9	0.19	7.3							
2	晴	22.0	10.0	0.18	7.3							
3	曇	23.6	10.2	0.19	7.3							
4	雨	18.0	10.1	0.18	7.5							
5	晴	23.0	10.1	0.18	7.3							
6	曇	19.0	10.2	0.20	7.5							
7	曇	19.5	10.0	0.21	7.3							
8	晴	18.0	10.0	0.19	7.3							
9	晴	19.0	10.1	0.20	7.3							
10	晴	18.5	10.0	0.18	7.5							
11	晴	22.2	10.1	0.18	7.3							
12	晴	24.0	10.0	0.20	7.3							
13	晴	25.0	10.0	0.23	7.2	50.0	84.0	121	1.3	<0.01	<0.02	
14	晴	23.0	10.1	0.24	7.3							
15	晴	23.5	10.1	0.20	7.3							
16	雨	19.0	10.2	0.21	7.3							
17	晴	22.0	10.1	0.18	7.5							
18	晴	22.8	10.2	0.20	7.2							
19	雨	19.8	10.2	0.20	7.3							
20	晴	20.0	10.1	0.20	7.2	51.0	82.0	127	1.3	<0.01	<0.02	
21	曇	17.5	10.0	0.19	7.2							
22	晴	19.0	10.0	0.20	7.2							
23	晴	20.9	10.1	0.19	7.3							
24	晴	23.0	10.2	0.20	7.4							
25	晴	24.8	10.2	0.22	7.2							
26	曇	24.5	10.3	0.22	7.2							
27	晴	26.2	10.3	0.22	7.3							
28	晴	23.8	10.3	0.23	7.5							
29	晴	22.5	10.4	0.23	7.2							
30	晴	23.8	10.5	0.23	7.2							
31	曇	23.5	10.5	0.22	7.6							
平均		21.7	10.1	0.20	7.3	50.5	83.0	124	1.3	<0.01	<0.02	
最高		26.2	10.5	0.24	7.6	51.0	84.0	127	1.3	<0.01	<0.02	
最低		17.5	9.9	0.18	7.2	50.0	82.0	121	1.3	<0.01	<0.02	