

令和 2年 8月分

静清工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (配水 : 配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	28.5	12.0	0.28	7.3							
2	晴	32.0	12.1	0.21	7.3							
3	晴	27.9	12.1	0.22	7.2							
4	曇	29.2	12.0	0.22	7.0							
5	晴	30.5	12.0	0.24	7.0	56.0	76.0	134	1.3	<0.01	<0.02	
6	晴	30.0	12.1	0.22	7.3							
7	晴	30.5	12.1	0.23	7.0							
8	晴	30.0	12.3	0.22	7.0							
9	晴	32.2	12.4	0.20	7.0							
10	晴	30.3	12.5	0.21	7.1							
11	晴	32.8	12.4	0.21	7.3							
12	晴	31.3	12.5	0.21	7.0							
13	晴	31.8	12.5	0.21	7.2							
14	晴	31.5	12.6	0.22	7.1							
15	晴	31.0	12.7	0.22	7.0							
16	晴	33.1	12.8	0.20	7.2							
17	曇	32.8	12.8	0.20	7.1							
18	晴	31.0	12.7	0.20	7.1							
19	晴	30.5	12.7	0.21	7.0	53.0	76.0	122	1.2	<0.01	<0.02	
20	晴	32.0	12.7	0.19	7.0							
21	曇	31.5	12.7	0.21	7.1							
22	晴	31.0	12.9	0.20	7.0							
23	曇	26.5	12.9	0.19	7.1							
24	晴	29.2	12.7	0.21	7.1							
25	晴	29.0	12.8	0.20	7.0							
26	晴	29.5	12.9	0.20	7.0							
27	晴	30.2	12.9	0.21	7.1							
28	曇	27.0	12.9	0.22	7.1							
29	晴	29.5	12.9	0.23	7.1							
30	晴	32.3	13.0	0.20	7.2							
31	晴	30.0	13.0	0.21	7.1							
平均		30.5	12.6	0.21	7.1	54.5	76.0	128	1.3	<0.01	<0.02	
最高		33.1	13.0	0.28	7.3	56.0	76.0	134	1.3	<0.01	<0.02	
最低		26.5	12.0	0.19	7.0	53.0	76.0	122	1.2	<0.01	<0.02	