

令和 3年 2月分

静清工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (配水 : 配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	8.6	14.5	0.00	7.3							
2	曇	13.5	14.5	0.22	7.4							
3	晴	7.0	14.5	0.00	7.5	54.0	83.0	111	1.3	<0.01	<0.02	
4	晴	6.2	14.5	0.05	7.7							
5	晴	5.0	14.4	0.00	7.3							
6	晴	9.1	14.4	0.00	7.3							
7	晴	7.5	14.4	0.01	7.4							
8	晴	10.3	14.4	0.00	7.6							
9	晴	4.2	14.3	0.00	7.7							
10	晴	5.2	14.3	0.01	7.6							
11	晴	7.1	14.3	0.00	7.7							
12	曇	9.0	14.3	0.04	7.7							
13	晴	11.0	14.3	0.06	7.3							
14	晴	12.8	14.3	0.00	7.4							
15	雨	12.2	14.4	0.00	7.4							
16	晴	10.0	14.3	0.00	7.3							
17	晴	9.1	14.3	0.00	7.5							
18	晴	3.0	14.3	0.01	7.6	53.0	83.0	125	1.4	<0.01	<0.02	
19	晴	4.0	14.2	0.00	7.2							
20	晴	5.0	14.1	0.00	7.3							
21	晴	13.7	14.3	0.00	7.3							
22	晴	8.7	14.4	0.00	7.3							
23	晴	16.0	14.4	0.00	7.5							
24	曇	9.0	14.3	0.00	7.3							
25	晴	9.0	14.3	0.00	7.6							
26	曇	11.0	14.2	0.00	7.3							
27	曇	9.8	14.2	0.00	7.4							
28	晴	7.0	14.2	0.00	7.2							
29												
30												
31												
平均		8.7	14.3	0.01	7.4	53.5	83.0	118	1.4	<0.01	<0.02	
最高		16.0	14.5	0.22	7.7	54.0	83.0	125	1.4	<0.01	<0.02	
最低		3.0	14.1	0.00	7.2	53.0	83.0	111	1.3	<0.01	<0.02	