

令和 3年 3月分

静岡工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 ℃	水質試験結果報告書 (配水 : 配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	13.0	14.2	0.00	7.5							
2	雨	13.8	14.2	0.00	7.4							
3	晴	10.5	14.2	0.00	7.3							
4	晴	10.2	14.2	0.00	7.5							
5	曇	13.2	14.2	0.00	7.3							
6	曇	14.0	14.2	0.00	7.6							
7	曇	9.8	14.3	0.00	7.5							
8	曇	9.5	14.2	0.00	7.3							
9	晴	11.0	14.1	0.00	7.3							
10	晴	13.0	14.1	0.00	7.5	54.0	89.0	129	1.4	0.03	<0.02	
11	晴	11.8	14.2	0.00	7.3							
12	曇	13.5	14.2	0.00	7.6							
13	雨	10.8	14.1	0.00	7.3							
14	晴	11.8	14.1	0.04	7.3							
15	晴	13.0	14.2	0.08	7.2							
16	晴	14.8	14.2	0.06	7.5							
17	晴	16.8	14.3	0.00	7.3	55.0	88.0	123	1.4	<0.01	<0.02	
18	晴	13.2	14.3	0.04	7.3							
19	晴	14.8	14.3	0.01	7.3							
20	曇	15.2	14.3	0.07	7.2							
21	雨	15.0	14.3	0.01	7.3							
22	晴	15.9	14.2	0.54	7.2							
23	晴	11.8	14.3	0.10	7.2							
24	晴	12.8	14.2	0.05	7.2							
25	晴	15.8	14.1	0.04	7.2							
26	晴	14.2	14.1	0.09	7.2							
27	晴	14.0	14.2	0.05	7.3							
28	雨	15.5	14.2	0.00	7.2							
29	晴	19.0	14.2	1.06	7.2							
30	晴	17.2	14.3	0.00	7.3							
31	晴	18.8	14.3	0.00	7.5							
平均		13.7	14.2	0.07	7.3	55	89	126	1.4	0.02	<0.02	
最高		19.0	14.3	1.06	7.6	55	89	129	1.4	0.03	<0.02	
最低		9.5	14.1	0.00	7.2	54	88	123	1.4	<0.01	<0.02	