

令和3年4月分

静岡工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	18.2	14.4	0.00	7.4							
2	晴	17.0	14.4	0.00	7.3							
3	晴	17.7	14.5	0.00	7.3							
4	曇	21.5	14.5	0.00	7.2							
5	晴	19.6	14.5	0.00	7.4							
6	晴	13.2	14.3	0.00	7.2	54.8	83.7	116	1.4	<0.01	<0.02	
7	晴	14.4	14.3	0.01	7.2							
8	晴	15.8	14.4	0.00	7.3							
9	晴	13.5	14.4	0.00	7.2							
10	晴	10.5	14.4	0.06	7.2							
11	晴	13.3	14.4	0.00	7.5							
12	晴	16.0	14.4	0.00	7.2							
13	雨	15.0	14.4	0.01	7.3							
14	雨	18.0	14.4	0.02	7.4							
15	曇	12.0	14.4	0.00	7.2							
16	曇	16.0	14.3	0.01	7.2							
17	雨	15.0	14.3	0.05	7.2							
18	晴	16.5	14.3	0.03	7.5							
19	晴	15.2	14.3	0.00	7.2							
20	晴	17.0	14.3	0.00	7.2	53.8	82.6	118	1.3	<0.01	<0.02	
21	晴	19.0	14.5	0.03	7.2							
22	晴	20.0	14.5	0.02	7.2							
23	晴	15.0	14.5	0.05	7.5							
24	晴	16.0	14.5	0.06	7.3							
25	曇	19.0	14.6	0.03	7.5							
26	晴	15.4	14.6	0.00	7.2							
27	晴	16.0	14.5	0.05	7.2							
28	曇	21.0	14.7	0.05	7.2							
29	雨	16.3	14.6	0.06	7.6							
30	晴	19.0	14.6	0.26	7.3							
平均		16.4	14.4	0.03	7.3	54.3	83.2	117	1.4	<0.01	<0.02	
最高		21.5	14.7	0.26	7.6	54.8	83.7	118	1.4	<0.01	<0.02	
最低		10.5	14.3	0.00	7.2	53.8	82.6	116	1.3	<0.01	<0.02	