

令和3年5月分

静岡工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	20.5	14.7	0.12	7.2							
2	晴	18.0	14.7	0.05	7.2							
3	晴	17.0	14.7	0.05	7.3							
4	晴	18.8	14.8	0.01	7.2							
5	曇	21.5	14.8	0.05	7.2							
6	晴	21.2	14.8	0.05	7.5							
7	曇	19.1	14.9	0.08	7.5							
8	晴	18.5	14.8	0.00	7.2							
9	晴	24.2	15.0	0.00	7.2							
10	晴	21.0	15.0	0.02	7.4							
11	曇	20.8	15.1	0.07	7.2							
12	曇	20.0	15.0	0.04	7.3	51.7	75.6	146	1.3	<0.01	<0.02	
13	雨	17.0	15.0	0.08	7.3							
14	晴	23.0	15.0	0.05	7.4							
15	晴	22.7	15.2	0.03	7.5							
16	雨	20.5	15.3	0.05	7.4							
17	雨	23.8	15.2	0.08	7.2							
18	晴	25.0	15.2	0.10	7.5							
19	雨	21.2	15.3	0.13	7.2	52.7	74.2	129	1.3	<0.01	<0.02	
20	曇	23.2	15.3	0.10	7.2							
21	雨	22.8	15.4	0.14	7.2							
22	曇	20.6	15.4	0.27	7.1							
23	晴	20.9	15.4	0.19	7.1							
24	曇	23.5	15.4	0.13	7.5							
25	晴	23.0	15.4	0.17	7.4							
26	曇	22.2	15.4	0.15	7.5							
27	雨	14.8	15.5	0.19	7.3							
28	晴	21.2	15.4	0.21	7.5							
29	晴	24.8	15.5	0.17	7.5							
30	晴	23.3	15.6	0.17	7.3							
31	晴	22.8	15.7	0.19	7.1							
平均		21.2	15.2	0.10	7.3	52.2	74.9	138	1.3	<0.01	<0.02	
最高		25.0	15.7	0.27	7.5	52.7	75.6	146	1.3	<0.01	<0.02	
最低		14.8	14.7	0.00	7.1	51.7	74.2	129	1.3	<0.01	<0.02	