

様式一工水2 (A4用紙)

令和3年9月分

静清工業用水道 水質試験結果報告書（上原配水池）

採水時間 9:00

日	天候	気温 °C	水質試験結果（配水：配水池）									備考
			水温 °C	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	29.6	19.8	0.49	7.0	54.3	71.4	118	1.2	<0.01	<0.02	
2	曇	29.0	19.8	0.50	7.3							
3	曇	24.3	19.5	0.52	7.0							
4	曇	24.4	19.5	0.50	7.0							
5	曇	23.6	19.5	0.38	7.1							
6	曇	24.8	19.5	0.47	7.3							
7	晴	22.2	19.5	0.49	7.1							
8	晴	24.0	19.5	0.42	7.1							
9	雨	21.7	19.6	0.44	7.2							
10	晴	26.3	19.6	0.50	7.3							
11	曇	27.3	19.6	0.47	7.2							
12	曇	26.8	19.6	0.40	7.3							
13	曇	27.0	19.5	0.41	7.5							
14	曇	25.2	19.5	0.40	7.2							
15	晴	24.8	19.5	0.41	7.2	61.9	70.3	159	1.2	<0.01	<0.02	
16	晴	25.4	19.5	0.40	7.2							
17	曇	24.0	19.5	0.41	7.6							
18	雨	25.7	19.6	0.45	7.3							
19	晴	25.5	19.7	0.46	7.1							
20	晴	24.4	19.7	0.44	7.1							
21	晴	24.5	19.7	0.40	7.5							
22	雨	22.0	19.7	0.38	7.5							
23	晴	24.8	19.8	0.44	7.1							
24	晴	25.5	19.8	0.43	7.2							
25	晴	24.8	19.8	0.42	7.1							
26	曇	22.0	19.8	0.38	7.4							
27	晴	23.0	19.6	0.40	7.3							
28	晴	22.8	19.6	0.41	7.2							
29	晴	23.0	19.6	0.42	7.2							
30	曇	25.3	19.7	0.46	7.2							
平均		24.8	19.6	0.44	7.2	58.1	70.9	139	1.2	<0.01	<0.02	
最高		29.6	19.8	0.52	7.6	61.9	71.4	159	1.2	<0.01	<0.02	
最低		21.7	19.5	0.38	7.0	54.3	70.3	118	1.2	<0.01	<0.02	