

令和3年12月分

静岡工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	17.0	17.4	0.36	7.3							
2	晴	8.0	17.3	0.06	7.6							
3	晴	10.2	17.2	0.06	7.3							
4	晴	10.3	17.2	0.05	7.4							
5	曇	7.5	17.1	0.05	7.3							
6	曇	12.2	17.1	0.06	7.5	55.3	80.4	126	1.3	<0.01	<0.02	
7	曇	14.8	17.0	0.07	7.3							
8	曇	12.5	17.0	0.07	7.2							
9	晴	9.8	16.9	0.07	7.2							
10	晴	10.5	16.9	0.10	7.3							
11	晴	9.0	16.8	0.09	7.3							
12	晴	10.0	16.7	0.11	7.3							
13	晴	13.2	16.7	0.11	7.4							
14	曇	10.2	16.6	0.12	7.6							
15	晴	6.2	16.5	0.12	7.4							
16	晴	8.6	16.3	0.18	7.2							
17	曇	12.0	16.4	0.14	7.2							
18	晴	4.3	16.3	0.11	7.3							
19	晴	5.0	16.2	0.12	7.3							
20	晴	4.8	16.1	0.13	7.3							
21	晴	5.3	16.0	0.14	7.3	53.8	79.6	120	1.3	<0.01	<0.02	
22	晴	7.0	15.9	0.14	7.3							
23	曇	9.4	15.9	0.17	7.3							
24	晴	6.4	15.8	0.17	7.3							
25	晴	10.8	15.8	0.18	7.3							
26	晴	4.8	15.7	0.13	7.3							
27	晴	1.5	15.5	0.14	7.6							
28	晴	3.3	15.4	0.14	7.6							
29	晴	3.9	15.3	0.15	7.3							
30	晴	10.5	15.3	1.16	7.7							
31	晴	5.0	15.3	0.18	7.3							
平均		8.5	16.4	0.16	7.4	54.6	80.0	123	1.3	<0.01	<0.02	
最高		17.0	17.4	1.16	7.7	55.3	80.4	126	1.3	<0.01	<0.02	
最低		1.5	15.3	0.05	7.2	53.8	79.6	120	1.3	<0.01	<0.02	