

令和4年1月分

静岡工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	2.0	15.2	0.18	7.3							
2	晴	3.0	15.0	0.01	7.3							
3	晴	3.0	15.0	0.01	7.3							
4	晴	9.7	15.0	0.04	7.5							
5	晴	3.0	14.9	0.03	7.6							
6	曇	5.2	14.8	0.03	7.3							
7	晴	2.8	14.6	0.05	7.3							
8	晴	4.3	14.6	0.06	7.3							
9	晴	2.8	14.5	0.03	7.4							
10	晴	9.3	14.6	0.03	7.5							
11	雨	9.8	14.6	0.05	7.3	53.3	71.9	119	1.3	<0.01	<0.02	
12	晴	6.2	14.4	0.06	7.7							
13	晴	3.8	14.2	0.07	7.6							
14	晴	4.0	14.2	0.09	7.3							
15	晴	3.1	14.1	0.08	7.6							
16	晴	5.8	14.0	0.08	7.5							
17	晴	8.5	14.1	0.10	7.4							
18	晴	5.8	14.0	0.10	7.4	52.3	76.7	110	1.3	<0.01	<0.02	
19	曇	4.2	13.9	0.11	7.7							
20	曇	3.2	13.9	0.13	7.8							
21	晴	1.4	13.8	0.14	7.5							
22	晴	2.5	13.7	0.09	7.7							
23	曇	5.2	13.7	0.10	7.5							
24	曇	8.0	13.7	0.12	7.7							
25	曇	7.0	13.7	0.14	7.8							
26	晴	7.3	13.7	0.16	7.4							
27	晴	7.0	13.7	0.17	7.6							
28	晴	7.8	13.6	0.19	7.4							
29	晴	7.0	13.6	0.20	7.4							
30	曇	7.5	13.6	0.16	7.5							
31	晴	5.8	13.5	0.18	7.4							
平均		5.4	14.2	0.10	7.5	52.8	74.3	115	1.3	<0.01	<0.02	
最高		9.8	15.2	0.20	7.8	53.3	76.7	119	1.3	<0.01	<0.02	
最低		1.4	13.5	0.01	7.3	52.3	71.9	110	1.3	<0.01	<0.02	