

令和4年2月分

静岡工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	4.0	13.5	0.19	7.4	53.8	80.0	128	1.4	<0.01	<0.02	
2	晴	5.3	13.5	0.20	7.5							
3	曇	5.5	13.4	0.22	7.6							
4	晴	7.2	13.4	0.24	7.5							
5	晴	5.0	13.3	0.18	7.4							
6	晴	3.5	13.3	0.18	7.4							
7	晴	3.8	13.2	0.20	7.5							
8	曇	6.9	13.2	0.23	7.7							
9	晴	6.3	13.2	0.25	7.4							
10	雨	5.0	13.2	0.26	7.6							
11	晴	7.0	13.1	0.27	7.4							
12	晴	7.0	13.1	0.13	7.4							
13	曇	7.0	13.1	0.14	7.6							
14	曇	7.2	13.0	0.14	7.8							
15	晴	7.2	13.0	0.17	7.6	56.6	74.4	122	1.4	<0.01	<0.02	
16	晴	7.1	13.0	0.19	7.4							
17	晴	4.8	13.0	0.20	7.7							
18	晴	5.0	12.9	0.21	7.4							
19	曇	8.0	12.9	0.14	7.4							
20	曇	10.0	12.9	0.17	7.8							
21	晴	5.8	12.9	0.18	7.4							
22	晴	5.4	13.0	0.18	7.3							
23	晴	4.5	12.9	0.19	7.4							
24	晴	5.0	12.8	0.21	7.6							
25	晴	5.3	12.7	0.22	7.4							
26	晴	6.8	12.7	0.21	7.4							
27	晴	11.9	12.8	0.10	7.7							
28	晴	9.0	12.8	0.11	7.4							
平均		6.3	13.1	0.19	7.5	55.2	77.2	125	1.4	<0.01	<0.02	
最高		11.9	13.5	0.27	7.8	56.6	80.0	128	1.4	<0.01	<0.02	
最低		3.5	12.7	0.10	7.3	53.8	74.4	122	1.4	<0.01	<0.02	