

令和4年3月分

静岡工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	9.2	12.8	0.12	7.4							
2	晴	10.2	12.8	0.13	7.4	53.2	78.1	116	1.4	<0.01	<0.02	
3	晴	10.2	12.8	0.15	7.4							
4	曇	9.2	12.8	0.15	7.4							
5	晴	9.5	12.8	0.18	7.4							
6	晴	9.5	12.9	0.10	7.4							
7	晴	6.9	12.8	0.11	7.4							
8	晴	10.0	12.8	0.13	7.4							
9	晴	10.0	12.8	0.15	7.6							
10	晴	10.4	12.8	0.16	7.4							
11	晴	10.3	12.7	0.18	7.8							
12	晴	13.0	12.8	0.21	7.4							
13	晴	14.8	12.9	0.17	7.5							
14	晴	16.8	13.0	0.35	7.4							
15	晴	21.0	13.1	0.05	7.6	53.2	81.6	126	1.4	<0.01	<0.02	
16	晴	15.8	13.2	0.05	7.4							
17	晴	15.8	13.1	0.06	7.7							
18	曇	13.0	13.1	0.08	7.3							
19	曇	14.0	13.0	0.13	7.5							
20	晴	12.2	13.0	0.05	7.4							
21	曇	11.0	13.0	0.05	7.5							
22	雨	9.0	12.9	0.09	7.4							
23	晴	8.0	12.7	0.09	7.4							
24	晴	10.0	12.8	0.11	7.3							
25	晴	13.2	12.9	0.12	7.3							
26	曇	15.0	13.0	0.13	7.5							
27	曇	19.0	13.1	0.30	7.4							
28	晴	16.0	13.1	0.14	7.3							
29	曇	13.2	13.1	0.11	7.3							
30	曇	15.5	13.0	0.10	7.4							
31	晴	17.0	13.2	0.11	7.3							
平均		12.5	12.9	0.13	7.4	53.2	79.9	121	1.4	<0.01	<0.02	
最高		21.0	13.2	0.35	7.8	53.2	81.6	126	1.4	<0.01	<0.02	
最低		6.9	12.7	0.05	7.3	53.2	78.1	116	1.4	<0.01	<0.02	