

令和4年7月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	29.0	17.2	0.00	7.2							
2	曇	28.7	17.4	0.00	7.4							
3	曇	29.6	17.3	0.01	7.5							
4	雨	28.2	17.2	0.00	7.2							
5	雨	23.0	17.2	0.00	7.5							
6	晴	29.0	17.2	0.03	7.3	52.7	75.9	141	1.3	<0.01	<0.02	
7	曇	26.3	17.3	0.02	7.3							
8	曇	28.8	17.4	0.02	7.2							
9	曇	26.0	17.4	0.04	7.5							
10	曇	26.0	17.5	0.01	7.5							
11	晴	29.0	17.5	0.01	7.2							
12	曇	27.8	17.7	0.01	7.2							
13	晴	27.8	17.6	0.01	7.5							
14	曇	27.2	17.7	0.02	7.4							
15	雨	24.0	17.7	0.02	7.3							
16	曇	26.0	17.7	0.03	7.2							
17	雨	24.0	18.0	0.51	7.0							
18	曇	27.5	18.0	0.01	7.1							
19	雨	25.2	18.1	0.01	7.3							
20	晴	29.8	18.0	0.01	7.3	59.4	84.1	138	1.3	<0.01	<0.02	
21	晴	29.6	18.2	0.00	7.4							
22	曇	25.0	18.2	0.01	7.3							
23	晴	29.1	18.3	0.00	7.1							
24	晴	30.0	18.5	0.01	7.3							
25	晴	29.5	18.5	0.01	7.2							
26	雨	25.2	18.7	0.01	7.3							
27	曇	29.0	18.8	0.04	7.1							
28	晴	30.3	18.7	0.33	7.1							
29	晴	30.6	18.8	0.01	7.4							
30	晴	30.5	18.9	0.01	7.1							
31	晴	32.0	19.0	0.01	7.4							
平均		27.9	17.9	0.04	7.3	56.1	80.0	140	1.3	<0.01	<0.02	
最高		32.0	19.0	0.51	7.5	59.4	84.1	141	1.3	<0.01	<0.02	
最低		23.0	17.2	0.00	7.0	52.7	75.9	138	1.3	<0.01	<0.02	