

令和5年3月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	12.8	14.2	0.00	7.6							
2	晴	8.8	14.2	0.00	7.5							
3	曇	8.9	14.2	0.00	7.9							
4	晴	10.5	14.2	0.00	7.7							
5	曇	11.5	14.2	0.01	7.7							
6	晴	11.0	14.1	0.01	7.5							
7	晴	11.2	14.4	0.00	7.9							
8	晴	12.0	14.3	0.00	7.6	54.1	81.9	140	1.4	<0.01	<0.02	
9	晴	14.0	14.4	0.01	7.5							
10	晴	16.2	14.4	0.01	7.8							
11	晴	15.0	14.5	0.00	7.5							
12	晴	15.2	14.5	0.00	7.5							
13	雨	14.3	14.5	0.00	7.7							
14	晴	11.9	14.3	0.00	7.9							
15	曇	13.5	14.4	0.00	7.5							
16	晴	15.8	14.4	0.01	7.6							
17	晴	16.0	14.5	0.01	7.7							
18	雨	12.0	14.4	0.01	7.6							
19	曇	11.0	14.3	0.00	7.8							
20	晴	12.9	14.3	0.00	7.6							
21	曇	15.8	14.3	0.00	7.4							
22	晴	18.0	14.3	0.02	7.5	53.6	76.6	146	1.4	<0.01	<0.02	
23	雨	16.4	14.5	0.00	7.5							
24	晴	22.0	15.4	0.09	7.4							
25	雨	13.3	15.5	0.00	7.7							
26	雨	14.5	15.3	0.01	7.6							
27	晴	16.5	15.2	0.05	7.7							
28	晴	14.0	15.2	0.02	7.4							
29	晴	14.5	15.3	0.01	7.5							
30	晴	15.3	15.3	0.01	7.4							
31	曇	16.2	15.3	0.01	7.7							
平均		13.9	14.6	0.01	7.6	53.9	79.3	143	1.4	<0.01	<0.02	
最高		22.0	15.5	0.09	7.9	54.1	81.9	146	1.4	<0.01	<0.02	
最低		8.8	14.1	0.00	7.4	53.6	76.6	140	1.4	<0.01	<0.02	