

令和5年7月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガニ mg/l	
1	雨	24.0	18.5	0.18	7.4							
2	曇	26.0	18.5	0.12	7.4							
3	曇	28.5	18.5	0.09	7.3							
4	曇	28.0	18.6	0.12	7.4							
5	曇	27.5	18.5	0.10	7.4	54.9	81.8	125	1.3	<0.01	<0.02	
6	晴	27.8	18.6	0.11	7.4							
7	晴	29.4	18.8	0.10	7.4							
8	晴	29.6	19.0	0.09	7.4							
9	晴	31.0	19.0	0.07	7.4							
10	晴	29.2	19.0	0.08	7.5							
11	晴	29.8	19.2	0.11	7.4							
12	晴	30.0	19.3	0.10	7.4							
13	雨	26.1	19.3	0.09	7.5							
14	曇	28.9	19.2	0.10	7.6							
15	曇	27.7	19.4	0.10	7.6							
16	晴	31.0	19.5	0.05	7.5							
17	晴	31.5	19.6	0.06	7.3							
18	晴	32.0	19.8	0.10	7.4							
19	晴	31.0	19.9	0.09	7.4							
20	晴	31.4	20.0	0.08	7.3	54.1	77.4	123	1.2	<0.01	<0.02	
21	晴	28.4	20.0	0.07	7.4							
22	晴	28.2	20.0	0.06	7.4							
23	晴	29.5	20.1	0.04	7.3							
24	晴	29.1	20.2	0.10	7.4							
25	晴	30.8	20.3	0.14	7.4							
26	曇	29.0	20.3	0.15	7.4							
27	晴	30.2	20.4	0.09	7.4							
28	曇	30.9	20.6	0.09	7.3							
29	晴	31.9	20.6	0.06	7.3							
30	晴	31.7	20.8	0.05	7.4							
31	曇	32.9	20.7	0.05	7.2							
平均		29.5	19.6	0.09	7.4	54.5	79.6	124	1.3	<0.01	<0.02	
最高		32.9	20.8	0.18	7.6	54.9	81.8	125	1.3	<0.01	<0.02	
最低		24.0	18.5	0.04	7.2	54.1	77.4	123	1.2	<0.01	<0.02	