

## 様式一工水1 (A4用紙)

令和5年9月分

## 静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	30.0	22.1	0.13	7.2							
2	晴	29.5	22.2	0.10	7.2							
3	晴	29.7	22.2	0.10	7.3							
4	曇	30.0	22.2	0.13	7.1							
5	晴	30.2	22.2	0.12	7.3	57.0	80.2	138	1.6	<0.01	<0.02	
6	曇	28.2	22.2	0.11	7.2							
7	曇	26.8	22.0	0.11	7.1							
8	曇	24.8	22.0	0.11	7.3							
9	雨	27.2	22.0	0.10	7.3							
10	晴	27.6	22.0	0.09	7.2							
11	晴	29.0	22.1	0.11	7.2							
12	晴	28.2	22.2	0.09	7.3							
13	晴	28.1	22.2	0.09	7.3							
14	晴	29.6	22.3	0.10	7.3							
15	晴	30.0	22.3	0.10	7.6							
16	晴	30.2	22.4	0.10	7.1							
17	曇	30.3	22.3	0.10	7.2							
18	晴	31.0	22.4	0.11	7.3							
19	晴	29.2	22.5	0.16	7.2	56.8	82.1	143	1.6	<0.01	<0.02	
20	晴	29.6	22.5	0.14	7.3							
21	雨	27.8	21.8	0.14	7.3							
22	曇	27.4	21.2	0.17	7.4							
23	曇	24.5	21.2	0.10	7.4							
24	曇	25.0	21.2	0.10	7.3							
25	晴	25.5	21.1	0.11	7.3							
26	晴	25.5	21.1	0.11	7.4							
27	晴	26.8	21.2	0.14	7.2							
28	晴	28.2	21.2	0.16	7.1							
29	曇	28.1	21.3	0.17	7.3							
30	曇	27.0	21.3	0.15	7.2							
31												
平均		28.2	21.9	0.12	7.3	56.9	81.2	141	1.6	<0.01	<0.02	
最高		31.0	22.5	0.17	7.6	57.0	82.1	143	1.6	<0.01	<0.02	
最低		24.5	21.1	0.09	7.1	56.8	80.2	138	1.6	<0.01	<0.02	