

令和5年10月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)								備考	
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l		マン ガン mg/l
1	晴	31.0	21.3	0.13	7.2							
2	晴	26.0	21.2	0.15	7.1	56.9	80.7	115	1.5	<0.01	<0.02	
3	晴	25.0	21.2	0.17	7.2							
4	雨	19.5	21.1	0.21	7.3							
5	曇	22.9	21.0	0.24	7.2							
6	晴	19.9	20.9	0.22	7.1							
7	晴	21.2	20.9	0.24	7.1							
8	曇	20.3	20.8	0.14	7.1							
9	雨	17.0	20.6	0.14	7.1							
10	曇	22.5	20.6	0.18	7.2							
11	曇	22.4	20.6	0.31	7.2							
12	晴	21.0	20.7	0.21	7.2							
13	晴	20.8	20.6	0.30	7.1							
14	晴	19.0	20.6	0.24	7.1							
15	雨	16.1	20.5	0.13	7.1							
16	晴	18.8	20.5	0.31	7.1	62.0	73.0	119	1.6	<0.01	<0.02	
17	晴	19.8	20.5	0.18	7.3							
18	晴	20.6	20.5	0.18	7.2							
19	晴	20.0	20.5	0.18	7.2							
20	晴	23.1	20.5	0.39	7.3							
21	晴	19.5	20.4	0.14	7.2							
22	晴	16.1	20.3	0.09	7.3							
23	晴	16.0	20.2	0.09	7.1							
24	晴	18.0	20.2	0.10	7.2							
25	曇	19.0	20.2	0.11	7.2							
26	晴	17.8	20.1	0.13	7.2							
27	晴	17.8	20.1	0.13	7.2							
28	晴	18.2	20.1	0.11	7.2							
29	晴	16.1	20.0	0.09	7.3							
30	晴	17.0	20.0	0.11	7.5							
31	曇	18.3	19.9	0.13	7.2							
平均		20.0	20.5	0.18	7.2	59.5	76.9	117	1.6	<0.01	<0.02	
最高		31.0	21.3	0.39	7.5	62.0	80.7	119	1.6	<0.01	<0.02	
最低		16.0	19.9	0.09	7.1	56.9	73.0	115	1.5	<0.01	<0.02	