

令和5年12月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	11.0	18.4	0.12	7.3							
2	晴	7.9	18.2	0.08	7.3							
3	晴	8.0	18.1	0.06	7.3							
4	晴	7.9	18.0	0.06	7.4	60.6	81.8	136	1.6	<0.01	<0.02	
5	曇	8.5	17.9	0.07	7.3							
6	晴	12.8	17.9	0.08	7.2							
7	晴	14.0	17.9	0.10	7.2							
8	晴	9.0	17.8	0.10	7.3							
9	晴	9.6	17.8	0.07	7.3							
10	晴	9.4	17.7	0.04	7.3							
11	晴	12.0	17.7	0.05	7.3							
12	雨	14.0	17.7	0.07	7.3							
13	晴	12.8	17.7	0.09	7.3							
14	晴	11.2	17.6	0.09	7.5							
15	雨	12.3	17.6	0.15	7.3							
16	曇	21.0	17.7	0.08	7.3							
17	晴	11.3	17.5	0.06	7.3							
18	晴	7.0	17.3	0.07	7.2	58.6	79.4	155	1.6	<0.01	<0.02	
19	曇	8.8	17.2	0.08	7.3							
20	晴	8.0	17.2	0.09	7.3							
21	晴	7.6	17.1	0.13	7.4							
22	晴	4.5	16.9	0.11	7.3							
23	晴	2.5	16.8	0.07	7.4							
24	晴	4.1	16.7	0.04	7.3							
25	晴	4.5	16.6	0.07	7.2							
26	晴	5.2	16.6	0.05	7.3							
27	晴	7.1	16.6	0.06	7.3							
28	曇	9.5	16.6	0.08	7.3							
29	晴	7.0	16.5	0.09	7.3							
30	晴	6.5	16.5	0.10	7.4							
31	雨	9.2	16.5	0.06	7.4							
平均		9.2	17.4	0.08	7.3	59.6	80.6	146	1.6	<0.01	<0.02	
最高		21.0	18.4	0.15	7.5	60.6	81.8	155	1.6	<0.01	<0.02	
最低		2.5	16.5	0.04	7.2	58.6	79.4	136	1.6	<0.01	<0.02	