

令和6年1月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	10.0	16.5	0.01	7.4							
2	雨	8.5	16.4	0.02	7.4							
3	曇	8.0	16.3	0.02	7.4							
4	晴	8.9	16.3	0.04	7.4							
5	晴	9.2	16.2	0.04	7.2							
6	晴	6.5	16.1	0.05	7.5							
7	晴	9.7	16.2	0.03	7.3							
8	晴	6.0	16.0	0.03	7.2							
9	晴	4.2	15.9	0.05	7.4							
10	晴	6.2	15.8	0.05	7.4							
11	曇	8.6	15.8	0.06	7.3							
12	晴	4.0	15.7	0.08	7.3							
13	晴	9.0	15.7	0.05	7.4							
14	晴	4.0	15.7	0.02	7.3							
15	晴	12.6	15.7	0.03	7.4	54.3	86.7	133	1.6	<0.01	<0.02	
16	晴	5.0	15.5	0.03	7.3							
17	晴	5.0	15.4	0.04	7.3							
18	晴	7.6	15.4	0.05	7.3							
19	曇	13.5	15.5	0.07	7.4							
20	雨	8.0	15.5	0.04	7.4							
21	雨	10.4	15.3	0.06	7.4							
22	曇	14.0	15.3	0.07	7.2	54.2	81.4	142	1.6	<0.01	<0.02	
23	晴	9.4	15.4	0.05	7.4							
24	晴	3.6	15.2	0.05	7.2							
25	晴	4.8	15.1	0.06	7.3							
26	晴	3.0	15.0	0.08	7.4							
27	晴	4.3	15.0	0.06	7.4							
28	晴	7.5	15.0	0.00	7.4							
29	晴	6.2	14.9	0.01	7.2							
30	晴	8.5	15.0	0.02	7.3							
31	晴	7.2	15.1	0.01	7.3							
平均		7.5	15.6	0.04	7.3	54.3	84.1	138	1.6	<0.01	<0.02	
最高		14.0	16.5	0.08	7.5	54.3	86.7	142	1.6	<0.01	<0.02	
最低		3.0	14.9	0.00	7.2	54.2	81.4	133	1.6	<0.01	<0.02	