

令和6年2月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

| 日 | 天候 | 気温 °C | 水質試験結果 (配水:配水池) | | | | | | | | | 備考 |
|----|----|----------|-----------------|---------|-----|-------------------|------------|-------------------|--------------------|-----------|------------------|----|
| | | | 水温 °C | 濁度 度 | pH | アルカリ 度 mg/l | 硬度 mg/l | 蒸発 残留物 mg/l | 塩化物 イオン mg/l | 鉄 mg/l | マン ガン mg/l | |
| 1 | 晴 | 11.9 | 15.1 | 0.03 | 7.3 | | | | | | | |
| 2 | 曇 | 8.9 | 15.1 | 0.04 | 7.3 | | | | | | | |
| 3 | 曇 | 8.0 | 15.1 | 0.02 | 7.3 | | | | | | | |
| 4 | 雨 | 7.5 | 15.1 | 0.04 | 7.3 | | | | | | | |
| 5 | 曇 | 7.8 | 14.9 | 0.00 | 7.4 | 53.8 | 78.1 | 142 | 1.5 | <0.01 | <0.02 | |
| 6 | 雨 | 7.0 | 14.8 | 0.02 | 7.3 | | | | | | | |
| 7 | 曇 | 7.0 | 14.7 | 0.02 | 7.3 | | | | | | | |
| 8 | 晴 | 6.8 | 14.7 | 0.03 | 7.5 | | | | | | | |
| 9 | 晴 | 8.1 | 14.7 | 0.04 | 7.3 | | | | | | | |
| 10 | 晴 | 6.5 | 14.7 | 0.06 | 7.2 | | | | | | | |
| 11 | 晴 | 6.8 | 14.7 | 0.00 | 7.2 | | | | | | | |
| 12 | 晴 | 7.0 | 14.6 | 0.02 | 7.3 | | | | | | | |
| 13 | 晴 | 8.0 | 14.7 | 0.03 | 7.4 | | | | | | | |
| 14 | 晴 | 10.0 | 14.7 | 0.04 | 7.4 | | | | | | | |
| 15 | 晴 | 14.0 | 14.7 | 0.05 | 7.4 | | | | | | | |
| 16 | 晴 | 13.3 | 14.7 | 0.06 | 7.2 | | | | | | | |
| 17 | 曇 | 11.5 | 14.7 | 0.08 | 7.6 | | | | | | | |
| 18 | 曇 | 13.8 | 14.7 | 0.01 | 7.6 | | | | | | | |
| 19 | 雨 | 13.8 | 14.8 | 0.04 | 7.3 | 53.6 | 75.7 | 159 | 1.5 | <0.01 | <0.02 | |
| 20 | 晴 | 18.7 | 14.7 | 0.71 | 7.2 | | | | | | | |
| 21 | 曇 | 13.0 | 14.7 | 0.22 | 7.3 | | | | | | | |
| 22 | 雨 | 9.0 | 14.6 | 0.13 | 7.2 | | | | | | | |
| 23 | 雨 | 7.0 | 14.3 | 0.14 | 7.3 | | | | | | | |
| 24 | 晴 | 7.0 | 14.3 | 0.09 | 7.3 | | | | | | | |
| 25 | 雨 | 5.0 | 14.2 | 0.03 | 7.3 | | | | | | | |
| 26 | 晴 | 9.0 | 14.2 | 0.03 | 7.4 | | | | | | | |
| 27 | 晴 | 9.1 | 14.2 | 0.04 | 7.2 | | | | | | | |
| 28 | 晴 | 8.2 | 14.2 | 0.04 | 7.3 | | | | | | | |
| 29 | 晴 | 9.9 | 14.2 | 0.05 | 7.3 | | | | | | | |
| 30 | | | | | | | | | | | | |
| 31 | | | | | | | | | | | | |
| 平均 | | 9.4 | 14.6 | 0.07 | 7.3 | 53.7 | 76.9 | 151 | 1.5 | <0.01 | <0.02 | |
| 最高 | | 18.7 | 15.1 | 0.71 | 7.6 | 53.8 | 78.1 | 159 | 1.5 | <0.01 | <0.02 | |
| 最低 | | 5.0 | 14.2 | 0.00 | 7.2 | 53.6 | 75.7 | 142 | 1.5 | <0.01 | <0.02 | |