

令和6年3月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	9.6	14.2	0.07	7.3							
2	晴	7.7	14.2	0.04	7.3							
3	晴	7.2	14.2	0.00	7.3							
4	晴	10.1	14.2	0.01	7.3	52.2	74.2	143	1.6	<0.01	<0.02	
5	曇	10.2	14.1	0.02	7.3							
6	曇	10.3	14.0	0.06	7.3							
7	曇	8.8	14.0	0.04	7.3							
8	晴	8.6	14.0	0.03	7.2							
9	晴	8.9	14.0	0.05	7.2							
10	晴	6.8	14.0	0.00	7.2							
11	晴	8.9	14.0	0.01	7.2	52.8	73.2	130	1.6	<0.01	<0.02	
12	雨	9.0	14.0	0.04	7.3							
13	晴	10.2	13.9	0.29	7.3							
14	晴	9.9	14.0	0.10	7.3							
15	晴	11.2	14.0	0.09	7.2							
16	晴	13.0	14.1	0.07	7.6							
17	晴	16.4	14.1	0.05	7.2							
18	晴	14.6	14.1	0.05	7.7							
19	曇	11.8	14.1	0.05	7.3							
20	晴	13.5	14.0	0.05	7.4							
21	晴	7.6	14.0	0.06	7.4							
22	晴	12.4	13.9	0.07	7.4							
23	雨	7.1	13.9	0.03	7.3							
24	曇	11.0	13.8	0.01	7.4							
25	雨	12.8	13.8	0.02	7.3							
26	雨	10.8	13.7	0.08	7.4							
27	晴	12.9	13.7	0.12	7.3							
28	曇	13.0	13.8	0.06	7.3							
29	雨	16.5	13.9	1.93	7.3							
30	晴	20.5	14.1	0.79	7.3							
31	晴	21.0	14.2	0.17	7.2							
平均		11.4	14.0	0.14	7.3	52.5	73.7	137	1.6	<0.01	<0.02	
最高		21.0	14.2	1.93	7.7	52.8	74.2	143	1.6	<0.01	<0.02	
最低		6.8	13.7	0.00	7.2	52.2	73.2	130	1.6	<0.01	<0.02	