

令和6年4月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	19.5	14.2	0.13	7.1	54.0	75.5	137	1.6	<0.01	<0.02	
2	晴	15.5	14.2	0.12	7.1							
3	雨	15.0	14.2	0.10	7.3							
4	曇	16.8	14.1	0.14	7.4							
5	曇	15.0	14.0	0.14	7.3							
6	晴	15.4	14.0	0.09	7.3							
7	晴	18.0	14.2	0.06	7.3							
8	曇	19.9	14.2	0.08	7.1							
9	雨	19.0	14.3	0.07	7.4							
10	晴	16.5	14.2	0.24	7.3							
11	晴	15.4	14.2	0.14	7.3							
12	曇	17.9	14.3	0.12	7.3							
13	晴	17.8	14.3	0.10	7.3							
14	晴	19.0	14.4	0.07	7.3							
15	晴	18.3	14.4	0.09	7.1	51.0	69.4	143	1.5	<0.01	<0.02	
16	晴	20.6	14.5	0.08	7.3							
17	曇	19.2	14.6	0.08	7.2							
18	曇	20.3	14.6	0.09	7.3							
19	晴	19.9	14.5	0.09	7.3							
20	晴	20.5	14.7	0.07	7.3							
21	曇	21.0	14.7	0.05	7.3							
22	曇	18.2	14.7	0.06	7.1							
23	曇	20.0	14.6	0.06	7.5							
24	雨	15.2	14.6	0.06	7.2							
25	晴	20.1	14.6	0.06	7.4							
26	晴	22.6	14.7	0.07	7.2							
27	曇	18.7	14.8	0.08	7.3							
28	晴	23.2	14.8	0.07	7.2							
29	曇	22.7	15.0	0.08	7.5							
30	曇	22.2	15.0	0.08	7.3							
31												
平均		18.8	14.5	0.09	7.3	52.5	72.5	140	1.6	<0.01	<0.02	
最高		23.2	15.0	0.24	7.5	54.0	75.5	143	1.6	<0.01	<0.02	
最低		15.0	14.0	0.05	7.1	51.0	69.4	137	1.5	<0.01	<0.02	