

令和6年5月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	22.2	15.0	0.09	7.3							
2	曇	17.1	14.9	0.10	7.3							
3	晴	19.5	14.9	0.11	7.3							
4	晴	21.8	15.0	0.11	7.4							
5	晴	21.5	15.2	0.07	7.6							
6	曇	22.8	15.3	0.07	7.2							
7	雨	19.3	15.2	0.11	7.3	56.2	72.5	135	1.6	<0.01	<0.02	
8	晴	21.2	15.2	0.13	7.3							
9	曇	16.8	15.2	0.12	7.2							
10	晴	18.2	15.2	0.14	7.1							
11	晴	20.3	15.5	0.15	7.2							
12	曇	23.0	15.6	0.07	7.5							
13	雨	20.4	15.7	0.09	7.5							
14	晴	19.2	15.7	0.19	7.2							
15	晴	21.7	15.7	0.14	7.2							
16	雨	19.0	15.7	0.14	7.3							
17	晴	21.8	15.8	0.15	7.3							
18	晴	23.3	15.9	0.16	7.2							
19	曇	21.7	15.9	0.08	7.2							
20	曇	20.0	15.9	0.10	7.1	53.7	73.2	154	1.5	<0.01	<0.02	
21	曇	24.0	16.0	0.12	7.1							
22	曇	22.0	16.1	0.11	7.3							
23	曇	21.2	16.0	0.11	7.2							
24	曇	23.9	16.1	0.12	7.3							
25	曇	23.9	16.2	0.13	7.1							
26	曇	23.3	16.2	0.09	7.4							
27	雨	22.8	16.3	0.10	7.2							
28	雨	23.5	16.4	0.10	7.3							
29	曇	23.0	16.4	0.36	7.2							
30	晴	24.5	16.5	0.20	7.2							
31	雨	19.4	16.5	0.16	7.2							
平均		21.4	15.7	0.13	7.3	55.0	72.9	145	1.6	<0.01	<0.02	
最高		24.5	16.5	0.36	7.6	56.2	73.2	154	1.6	<0.01	<0.02	
最低		16.8	14.9	0.07	7.1	53.7	72.5	135	1.5	<0.01	<0.02	