

令和6年6月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	22.8	16.5	0.13	7.3							
2	曇	23.1	16.6	0.13	7.2							
3	晴	22.0	16.5	0.16	7.3	51.6	74.2	166	1.5	<0.01	<0.02	
4	晴	22.0	16.6	0.13	7.3							
5	晴	22.3	16.6	0.15	7.2							
6	晴	25.1	16.7	0.15	7.2							
7	晴	24.3	16.8	0.17	7.2							
8	晴	24.0	16.9	0.14	7.2							
9	曇	22.7	17.0	0.11	7.2							
10	曇	23.0	17.0	0.10	7.4							
11	晴	26.0	17.0	0.13	7.3							
12	晴	27.1	17.1	0.14	7.2							
13	曇	24.6	17.2	0.15	7.2							
14	晴	27.4	17.1	0.16	7.2							
15	晴	25.8	17.3	0.17	7.3							
16	曇	23.5	17.3	0.10	7.5							
17	晴	28.0	17.2	0.14	7.2	50.4	71.0	169	1.5	<0.01	<0.02	
18	雨	19.0	17.2	0.20	7.2							
19	晴	24.6	17.2	0.28	7.2							
20	晴	26.8	17.3	0.17	7.6							
21	雨	23.3	17.3	0.16	7.1							
22	晴	25.0	17.3	0.18	7.0							
23	雨	20.4	17.4	0.12	7.1							
24	晴	28.7	17.5	0.18	7.4							
25	曇	29.5	17.7	0.17	7.2							
26	晴	30.0	17.8	0.18	7.2							
27	晴	28.0	17.8	0.18	7.1							
28	雨	21.9	18.1	0.73	7.2							
29	曇	24.5	18.2	0.67	7.1							
30	曇	29.0	18.1	0.22	7.2							
31												
平均		24.8	17.2	0.19	7.2	51.0	72.6	168	1.5	<0.01	<0.02	
最高		30.0	18.2	0.73	7.6	51.6	74.2	169	1.5	<0.01	<0.02	
最低		19.0	16.5	0.10	7.0	50.4	71.0	166	1.5	<0.01	<0.02	