

令和6年7月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	31.8	18.2	0.22	7.6	58.4	69.6	164	1.4	<0.01	<0.02	
2	曇	27.3	18.0	0.19	7.2							
3	曇	29.7	18.1	0.21	7.2							
4	晴	30.2	18.4	0.23	7.2							
5	晴	31.2	18.5	0.24	7.2							
6	曇	30.2	18.7	0.19	7.2							
7	晴	31.0	18.8	0.15	7.2							
8	晴	31.2	18.8	0.25	7.0							
9	曇	31.9	18.9	0.18	7.2							
10	晴	30.0	19.0	0.18	7.2							
11	曇	30.1	18.9	0.19	7.5							
12	雨	26.2	18.7	0.19	7.0							
13	曇	26.9	18.6	0.22	7.1							
14	雨	25.8	18.7	0.16	7.1							
15	曇	32.1	19.0	0.17	7.1							
16	雨	24.5	18.9	0.27	7.2							
17	曇	29.0	19.0	0.23	7.1	53.2	68.4	150	1.4	<0.01	<0.02	
18	晴	29.4	19.0	0.25	7.4							
19	曇	31.8	19.2	0.20	7.2							
20	晴	33.5	19.3	0.2	7.20							
21	晴	31.0	19.5	0.14	7.1							
22	晴	31.0	19.6	0.17	7.4							
23	晴	32.5	19.7	0.17	7.2							
24	晴	31.8	19.7	0.15	7.2							
25	晴	31.5	19.8	0.15	7.1							
26	晴	30.2	19.8	0.15	7.2							
27	晴	32.5	19.9	0.13	7.2							
28	晴	32.0	19.9	0.12	7.2							
29	晴	33.5	19.9	0.13	7.0							
30	晴	34.0	20.0	0.12	7.2							
31	晴	33.0	20.0	0.15	7.2							
平均		30.5	19.1	0.18	7.2	55.8	69.0	157	1.4	<0.01	<0.02	
最高		34.0	20.0	0.27	7.6	58.4	69.6	164	1.4	<0.01	<0.02	
最低		24.5	18.0	0.12	7.0	53.2	68.4	150	1.4	<0.01	<0.02	