

令和6年8月分

## 静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガン mg/l	
1	晴	30.8	20.0	0.14	7.5							
2	晴	31.1	20.1	0.15	7.2							
3	曇	30.9	20.2	0.12	7.3							
4	晴	32.0	20.3	0.10	7.2							
5	晴	32.2	20.3	0.14	7.3	51.6	73.1	138	1.4	<0.02	<0.02	
6	晴	31.8	20.3	0.14	7.2							
7	曇	31.0	20.4	0.16	7.2							
8	晴	30.0	20.4	0.14	7.2							
9	晴	32.2	20.5	0.14	7.2							
10	晴	30.8	20.6	0.12	7.2							
11	晴	32.5	20.6	0.10	7.1							
12	晴	32.1	20.7	0.10	7.2							
13	晴	31.8	20.6	0.12	7.4							
14	晴	31.0	20.8	0.13	7.2							
15	晴	31.2	20.8	0.14	7.2							
16	曇	33.0	20.8	0.14	7.1							
17	晴	31.2	20.8	0.14	7.1							
18	曇	30.7	20.9	0.07	7.1							
19	晴	32.8	20.8	0.12	7.1	53.1	76.7	129	1.5	<0.02	<0.02	
20	曇	31.0	20.7	0.10	7.2							
21	曇	30.8	20.8	0.10	7.3							
22	曇	30.2	20.8	0.11	7.2							
23	曇	28.8	20.9	0.12	7.2							
24	晴	31.5	20.9	0.09	7.2							
25	曇	30.7	20.9	0.09	7.2							
26	晴	29.0	20.8	0.10	7.1							
27	雨	25.2	20.9	0.12	7.2							
28	雨	25.7	21.1	0.24	7.1							
29	雨	24.9	21.0	0.20	6.9							
30	雨	26.3	21.6	1.50	6.8							
31	曇	28.0	21.5	0.32	7.2							
平均		30.4	20.7	0.18	7.2	52.4	74.9	134	1.5	<0.02	<0.02	
最高		33.0	21.6	1.50	7.5	53.1	76.7	138	1.5	<0.02	<0.02	
最低		24.9	20.0	0.07	6.8	51.6	73.1	129	1.4	<0.02	<0.02	