

令和6年10月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	25.4	21.1	0.14	7.3							
2	晴	26.1	21.1	0.14	7.3	53.2	73.9	132	1.5	<0.02	<0.02	
3	晴	26.9	21.1	0.22	7.3							
4	雨	25.2	21.2	0.37	7.2							
5	雨	25.2	21.2	0.18	7.3							
6	晴	23.7	21.2	0.24	7.2							
7	晴	26.1	21.1	0.19	7.1							
8	曇	25.8	21.1	0.19	7.2							
9	雨	18.4	20.8	0.23	7.3							
10	曇	20.7	20.7	0.24	7.3							
11	晴	21.2	20.7	0.20	7.6							
12	晴	22.3	20.7	0.19	7.3							
13	晴	23.0	20.7	0.10	7.2							
14	晴	22.6	20.8	0.08	7.3							
15	晴	24.0	20.8	0.11	7.3							
16	曇	23.2	20.7	0.11	7.4	56.6	75.7	116	1.5	<0.02	<0.02	
17	晴	25.0	20.7	0.12	7.3							
18	曇	24.2	20.7	0.13	7.3							
19	晴	26.1	20.7	0.10	7.3							
20	曇	18.5	20.6	0.09	7.3							
21	晴	18.4	20.4	0.10	7.3							
22	曇	22.0	20.4	0.12	7.4							
23	雨	21.0	20.4	0.13	7.3							
24	晴	23.8	20.4	0.14	7.3							
25	曇	23.0	20.4	0.14	7.3							
26	曇	21.1	20.3	0.11	7.3							
27	曇	21.0	20.3	0.09	7.3							
28	雨	21.0	20.2	0.11	7.2							
29	雨	17.7	20.1	0.10	7.4							
30	曇	18.9	20.1	0.14	7.3							
31	晴	18.6	20.0	0.14	7.3							
平均		22.6	20.7	0.15	7.3	54.9	74.8	124	1.5	<0.02	<0.02	
最高		26.9	21.2	0.37	7.6	56.6	75.7	132	1.5	<0.02	<0.02	
最低		17.7	20.0	0.08	7.1	53.2	73.9	116	1.5	<0.02	<0.02	