

令和7年1月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	6.0	16.2	0.00	7.5							
2	晴	5.0	16.2	0.00	7.5							
3	晴	6.0	16.1	0.00	7.5							
4	晴	5.0	16.0	0.00	7.5							
5	晴	4.5	16.0	0.00	7.5							
6	雨	6.8	15.9	0.00	7.3	49.4	72.7	116	1.4	<0.02	<0.02	
7	晴	9.8	15.9	0.00	7.5							
8	晴	5.0	15.8	0.00	7.6							
9	晴	7.1	15.7	0.00	7.5							
10	晴	2.9	15.6	0.00	7.5							
11	晴	2.6	15.6	0.00	7.6							
12	晴	6.2	15.5	0.00	7.6							
13	晴	6.2	15.5	0.00	7.4							
14	晴	4.9	15.6	0.00	7.5							
15	晴	10.1	15.6	0.00	7.5							
16	晴	5.0	15.5	0.00	7.8							
17	晴	3.9	15.4	0.00	7.7							
18	曇	7.2	15.4	0.00	7.6							
19	曇	7.0	15.4	0.00	7.3							
20	晴	9.0	15.4	0.00	7.4	50.3	70.1	114	1.5	<0.02	<0.02	
21	晴	10.0	15.4	0.00	7.6							
22	晴	6.9	15.3	0.00	7.5							
23	晴	6.8	15.2	0.00	7.4							
24	晴	7.4	15.2	0.00	7.6							
25	晴	9.5	15.2	0.00	7.5							
26	晴	8.3	15.2	0.00	7.6							
27	曇	6.8	15.1	0.00	7.4							
28	曇	7.8	15.0	0.00	7.6							
29	晴	6.2	15.0	0.00	7.5							
30	晴	5.9	14.9	0.00	7.5							
31	晴	4.0	14.8	0.00	7.5							
平均		6.4	15.5	0.00	7.5	49.9	71.4	115	1.5	<0.02	<0.02	
最高		10.1	16.2	0.00	7.8	50.3	72.7	116	1.5	<0.02	<0.02	
最低		2.6	14.8	0.00	7.3	49.4	70.1	114	1.4	<0.02	<0.02	