

令和7年7月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水 質 試 験 結 果 （ 配 水 : 配 水 池 ）									備 考
			水 温 °C	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	31.0	18.0	0.06	7.4							
2	曇	29.4	18.0	0.00	7.4							
3	曇	28.9	18.0	0.00	7.5							
4	曇	30.1	18.1	0.00	7.3							
5	晴	30.5	18.3	0.00	7.7							
6	晴	32.1	18.5	0.00	7.7							
7	晴	31.8	18.5	0.00	7.4	52.1	79.2	118	1.3	<0.02	<0.02	
8	晴	32.7	18.6	0.00	7.5							
9	晴	30.8	18.7	0.00	7.5							
10	晴	31.0	18.8	0.00	7.4							
11	晴	27.8	18.8	0.00	7.4							
12	曇	26.0	18.7	0.00	7.3							
13	晴	28.5	18.7	0.00	7.5							
14	晴	30.0	18.8	0.00	7.5	53.2	76.0	121	1.3	<0.02	<0.02	
15	雨	25.2	18.9	0.00	7.7							
16	雨	25.0	18.9	0.21	7.3							
17	曇	30.1	19.0	0.23	7.3							
18	晴	27.2	18.9	0.00	7.5							
19	晴	29.8	19.0	0.00	7.4							
20	晴	30.3	19.1	0.00	7.2							
21	晴	31.1	19.2	0.00	7.3							
22	晴	30.8	19.3	0.00	7.4							
23	晴	31.8	19.4	0.00	7.4							
24	晴	31.0	19.5	0.03	7.4							
25	晴	31.0	19.4	0.00	7.2							
26	晴	31.5	19.6	0.10	7.3							
27	晴	30.5	19.7	0.00	7.4							
28	晴	31.0	19.7	0.00	7.4							
29	晴	30.8	19.7	0.00	7.4							
30	晴	30.0	19.8	0.00	7.4							
31	晴	30.2	19.8	0.00	7.3							
平均		29.9	18.9	0.02	7.4	52.7	77.6	120	1.3	<0.02	<0.02	
最高		32.7	19.8	0.23	7.7	53.2	79.2	121	1.3	<0.02	<0.02	
最低		25.0	18.0	0.00	7.2	52.1	76.0	118	1.3	<0.02	<0.02	