

令和7年8月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水 質 試 験 結 果 （ 配 水 : 配 水 池 ）									備 考
			水 温 °C	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	30.9	19.8	0.00	7.3							
2	晴	31.9	19.9	0.00	7.4							
3	晴	32.8	20.0	0.00	7.4							
4	晴	33.3	20.0	0.00	7.7	53.1	77.4	135	1.2	<0.02	<0.02	
5	晴	31.9	20.0	0.02	7.4							
6	晴	31.9	20.1	0.00	7.4							
7	曇	32.8	20.1	0.00	7.4							
8	晴	30.8	20.0	0.00	7.5							
9	曇	30.7	20.0	0.00	7.6							
10	雨	27.2	20.0	0.00	7.4							
11	雨	26.6	20.2	0.00	7.2							
12	曇	29.8	20.2	0.02	7.4							
13	曇	30.2	20.2	0.00	7.3							
14	曇	28.2	20.2	0.00	7.3							
15	晴	29.6	20.3	0.00	7.3							
16	曇	27.9	20.3	0.00	7.4							
17	晴	29.4	20.3	0.00	7.3							
18	曇	30.3	20.3	0.00	7.2	54.7	77.0	157	1.2	<0.02	<0.02	
19	晴	30.4	20.3	0.00	7.3							
20	晴	30.0	20.4	0.00	7.4							
21	晴	30.3	20.6	0.00	7.4							
22	晴	30.5	20.6	0.07	7.3							
23	晴	30.9	20.7	0.01	7.4							
24	晴	31.9	20.8	0.02	7.4							
25	曇	31.0	20.7	0.00	7.2							
26	晴	31.3	20.9	0.00	7.4							
27	晴	30.5	20.9	0.00	7.4							
28	晴	31.3	20.9	0.07	7.4							
29	晴	30.0	20.8	0.00	7.4							
30	晴	30.3	20.9	0.00	7.4							
31	晴	31.2	21.1	0.00	7.4							
平均		30.5	20.4	0.01	7.4	53.9	77.2	146	1.2	<0.02	<0.02	
最高		33.3	21.1	0.07	7.7	54.7	77.4	157	1.2	<0.02	<0.02	
最低		26.6	19.8	0.00	7.2	53.1	77.0	135	1.2	<0.02	<0.02	