

令和8年5月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	15.8	15.2	0.05	7.4							
2	晴	18.5	15.3	0.00	7.4							
3	晴	21.6	15.5	0.00	7.4							
4	曇	22.6	15.7	0.15	7.4							
5	晴	19.7	15.7	0.02	7.4							
6	曇	20.1	15.7	0.00	7.4							
7	曇	22.2	15.7	0.00	7.4							
8	曇	22.7	15.8	0.02	7.4							
9	曇	21.3	15.8	0.00	7.4							
10	晴	21.0	15.8	0.00	7.4							
11	曇	21.2	15.8	0.00	7.4	54.1	78.5	131	1.3	<0.02	<0.02	
12	曇	21.4	15.9	0.00	7.4							
13	晴	21.4	16.0	0.00	7.4							
14	晴	22.7	16.0	0.00	7.4							
15	晴	20.3	16.1	0.00	7.4							
16	晴	21.3	16.2	0.00	7.4							
17	晴	21.6	16.3	0.00	7.4							
18	晴	24.2	16.2	0.00	7.4	54.2	79.2	123	1.3	<0.02	<0.02	
19	晴	23.4	16.3	0.00	7.4							
20	晴	23.7	16.4	0.00	7.4							
21	雨	24.0	16.5	0.00	7.4							
22	曇	20.9	16.2	0.00	7.4							
23	曇	18.0	16.1	0.00	7.4							
24	曇	21.3	16.1	0.00	7.4							
25	晴	22.1	16.2	0.00	7.4							
26	晴	24.0	16.4	0.00	7.4							
27	曇	24.2	16.5	0.01	7.4							
28	曇	25.0	16.2	0.00	7.4							
29	晴	24.9	16.5	0.01	7.4							
30	晴	25.5	16.6	0.00	7.4							
31	晴	24.3	16.8	0.00	7.4							
平均		22.0	16.0	0.01	7.4	54.2	78.9	127	1.3	<0.02	<0.02	
最高		25.5	16.8	0.15	7.4	54.2	79.2	131	1.3	<0.02	<0.02	
最低		15.8	15.2	0.00	7.4	54.1	78.5	123	1.3	<0.02	<0.02	